

GAS FIRE BOILERS

(Sept 1999)

3213

Tune all boilers at least twice annually unless equipped with automated combustion controls.

**FORMS AND/OR FORMS SAMPLES: RETURN TO ISSUANCE HOME PAGE
FOR FORMS/FORMS SAMPLES SITE LINK.**

[\(see next section\)](#)

[\(see Table of Contents\)](#)