



MANIPULATIVE PERFORMANCE TEST

Procedures Handbook 4300

MAKING AN OUT-OF-SERVICE HOSE ROLL – ONE PERSON METHOD

TOPIC/EQUIPMENT: Making An Out-of-Service Hose Roll - One Person Method

CATEGORY: Performance Examination

POINTS POSSIBLE: 100

TIME ALLOWED: Two Minutes

BEHAVIORAL OBJECTIVE:

Condition: One length of hose with male and female couplings

Behavior: The student will roll hose using the out-of-service hose roll - one person method.

Standard: With a minimum of 80% accuracy within two minutes

MATERIALS NEEDED:

- One (1) length of hose per student
- One (1) stop watch
- One (1) score sheet per student
- One (1) manipulative performance test cover page
- One (1) clip board
- One (1) red pen
- Appropriate fire safety PPE per CAL FIRE policy

PROCEDURES:

SCORING: Points will be deducted for each step omitted, performed improperly, or performed out of sequence. Steps designated by Pass/No Pass must be performed properly or the student fails the entire examination. If the student goes over the allotted time he/she will fail the entire examination.

SPECIAL NOTES:

Score Sheet

DATE ___ / ___ / ___ TEST # ___ RETEST # ___ UNIT # _____

STUDENT'S NAME _____

EVALUATOR'S NAME _____

POINTS

TIME START

- | | | |
|----|--|-----------|
| 1. | Lay out hose straight, flat, with no twists or kinks. | <u>20</u> |
| 2. | Grasp the female coupling and begin to roll it toward the male coupling keeping the rolled edges even. | <u>20</u> |
| 3. | Continue to roll hose until the male coupling is reached keeping the rolled edges even. | <u>20</u> |
| 4. | Lay rolled hose on its side and flatten the roll using care not to damage the couplings. | <u>10</u> |
| 5. | Secure the rolled hose with a rubber band or other restraining device. | <u>10</u> |
| 6. | Place hose in designated out-of-service area. | <u>20</u> |

TIME STOP

ENTER TOTAL TIME: ___:

POINTS POSSIBLE: 100

POINTS DEDUCTED: _____

FINAL SCORE: _____

4307.10

Page 2

Score Sheet

EVALUATOR'S SIGNATURE: _____

DATE: _____

COMMENTS:
