



NAME: \_\_\_\_\_

DATE: \_\_\_\_\_

---

---

**POINTS**

- |    |  |           |
|----|--|-----------|
| 1. | When inspecting fire extinguisher <b>locations</b> which of the following <b>does not</b> need to be visible?                    | <u>10</u> |
|    | a. Operating instructions  |           |
|    | b. Clearly identified  |           |
|    | c. Pressure gauge  |           |
|    | d. Proper location   |           |
| 2. | When checking extinguisher components to assure proper working order, which of the following <b>does not</b> need to be checked? | <u>10</u> |
|    | a. Locking pin   |           |
|    | b. Mounting bracket  |           |
|    | c. Manufacturers label   |           |
|    | d. Hose coupling   |           |
| 3. | What is <b>not</b> the purpose of fire extinguisher maintenance?   | <u>10</u> |
|    | a. Helps insure proper extinguisher operation  |           |
|    | b. Reduces risk of harm to the operator  |           |
|    | c. Visual inspection of all components   |           |
|    | d. Hydrostatic testing   |           |
| 4. | When is maintenance <b>not</b> required on fire extinguishers?   | <u>10</u> |
|    | a. When paint is faded   |           |
|    | b. Annually  |           |
|    | c. When there is evidence of damage  |           |
|    | d. After each use  |           |
| 5. | Hydrostatic testing for stored pressure fire extinguishers is required how often?  | <u>10</u> |
|    | a. Annually  |           |
|    | b. Every 5 years   |           |
|    | c. Every other year  |           |
|    | d. Bi-annually   |           |
| 6. | Halon extinguishers need to be hydrostatically tested?   | <u>10</u> |
|    | a. Every 5 years   |           |



**WRITTEN QUIZ**  
Procedures Handbook 4300

PORTABLE FIRE EXTINGUISHERS-  
INSPECTION, MAINTENANCE AND  
TESTING

- b. Annually
  - c. Every 12 years
  - d. Never
7. When inspecting the extinguisher locking pin, check to make sure the pin is unbroken and \_\_\_\_\_ 10
- a. In place
  - b. Not corroded
  - c. Missing parts
  - d. All of the above
8. When inspecting the manufacturers label make sure \_\_\_\_\_ 10
- a. Operating instructions are clearly legible
  - b. Rating and appropriate application instructions show
  - c. The recharging instructions show
  - d. All of the above
9. Maintenance on fire extinguishers are required to be conducted \_\_\_\_\_ 10
- a. Annually
  - b. After each use
  - c. When there is evidence of damage or tampering
  - d. All of the above
10. When inspecting the fire extinguisher hose and couplings which of the following needs to be checked? 10
- a. Hose/couplings are free of cuts, cracks and other damage
  - b. Couplings are secure
  - c. Free of corrosion
  - d. All of the above

**POINTS POSSIBLE:** 100

**POINTS DEDUCTED:** \_\_\_\_\_

**FINAL SCORE:** \_\_\_\_\_



	<b>KEY</b>	<b><u>POINTS</u></b>
1. When inspecting fire extinguisher <b><u>locations</u></b> which of the following <b><u>does not</u></b> need to be visible? e. Operating instructions f. Clearly identified <b>g. <u>Pressure gauge</u></b> h. Proper location Ref: TLP. Pg. 2, Sect. I.A.1.-5.		<u>10</u>
2. When checking extinguisher components to assure proper working order, which of the following <b><u>does not</u></b> need to be checked? e. Locking pin <b>f. <u>Mounting bracket</u></b> g. Manufacturers label h. Hose coupling Ref: TLP. Pgs. 2 & 3, Sect. I.B.1.-8.		<u>10</u>
3. What is <b><u>not</u></b> the purpose of fire extinguisher maintenance? e. Helps insure proper extinguisher operation f. Reduces risk of harm to the operator g. Visual inspection of all components <b>h. <u>Hydrostatic testing</u></b> Ref: TLP. Pg. 4, Sect. II. A. 1.-2.c.		<u>10</u>
4. When is maintenance <b><u>not</u></b> required on fire extinguishers? <b>e. <u>When paint is faded</u></b> f. Annually g. When there is evidence of damage h. After each use Ref: TLP. Pg. 4, Sect. II. B. 1.-4.		<u>10</u>
5. Hydrostatic testing for stored pressure fire extinguishers is required how often? e. Annually <b>f. <u>Every 5 years</u></b> g. Every other year h. Bi-annually Ref: TLP. Pg. 4, Sect. III. A. 1.		<u>10</u>
6. Halon extinguishers need to be hydrostatically tested?		<u>10</u>



	<b>KEY</b>	<b><u>POINTS</u></b>
	e. Every 5 years f. Annually <b>g. <u>Every 12 years</u></b> h. Never Ref: TLP. Pg. 4, Sect. III. A. 5.	
7.	When inspecting the extinguisher locking pin, check to make sure the pin is unbroken and _____. <b>e. <u>In place</u></b> f. Not corroded g. Missing parts h. All of the above Ref: TLP. Pg. 2, Sect. I. B. 1. a.-b.	<u>10</u>
8.	When inspecting the manufacturers label make sure _____. e. Operating instructions are clearly legible f. Rating and appropriate application instructions show g. The recharging instructions show <b>h. <u>All of the above</u></b> Ref: TLP. Pgs. 3 & 4, Sect. I. B. 3. a.-b.	<u>10</u>
9.	Maintenance on fire extinguishers are required to be conducted _____. e. Annually f. After each use g. When there is evidence of damage or tampering <b>h. <u>All of the above</u></b> Ref: TLP. Pg. 3, Sect. I. B. 4. a.-c.	<u>10</u>
10.	When inspecting the fire extinguisher hose and couplings which of the following needs to be checked? e. Hose/couplings are free of cuts, cracks and other damage f. Couplings are secure g. Free of corrosion <b>h. <u>All of the above</u></b> Ref: TLP. Pg. 3, Sect. I. B. 4. a.-c.	<u>10</u>



# WRITTEN QUIZ

Procedures Handbook 4300

PORTABLE FIRE EXTINGUISHERS-  
INSPECTION, MAINTENANCE AND  
TESTING

---

**POINTS POSSIBLE:**      100

**POINTS DEDUCTED:**      \_\_\_\_\_

**FINAL SCORE:**      \_\_\_\_\_