

- |   | <b><u>POINTS</u></b> |
|---|----------------------|
| 1. The plan for salvage and overhaul should be made to provide the highest degree of _____ for the firefighter. | <u>20</u>            |
| 2. Weakened ceilings should be _____ during salvage and overhaul operations.                                    | <u>20</u>            |
| 3. If your crew is extremely fatigued from firefighting operations, what might you consider doing?              | <u>20</u>            |
| 4. When hauling debris out of a structure, establish traffic _____ for firefighter safety.                      | <u>20</u>            |
| 5. Name four places where illumination should be provided during night operations to ensure firefighter safety. | <u>20</u>            |
| _____   |                      |
| _____   |                      |
| _____   |                      |
| _____   |                      |

**POINTS POSSIBLE:** 100

**POINTS DEDUCTED:**

**FINAL SCORE:**

- |   | <b><u>POINTS</u></b> |
|---|----------------------|
| 1. The plan for salvage and overhaul should be made to provide the highest degree of <b>SAFETY</b> for the firefighter. | <u>20</u>            |
| 2. Weakened ceilings should be <b>PULLED (PULLED DOWN)</b> during salvage and overhaul operations.                      | <u>20</u>            |
| 3. If your crew is extremely fatigued from firefighting operations, what might you consider doing?                      | <u>20</u>            |
| <b>BRING IN FRESH CREWS</b>   |                      |
| 4. When hauling debris out of a structure, establish traffic <b>LANES, ROUTES</b> for firefighter safety.               | <u>20</u>            |
| 5. Name four places where illumination should be provided during night operations to ensure firefighter safety.         | <u>20</u>            |

## **TRIPPING HAZARDS**

### **HOLES**

### **STAIRWAYS**

### **BARRICADED AREAS**

### **OTHER HAZARDOUS AREAS**

**POINTS POSSIBLE:** 100

**POINTS DEDUCTED:**

**FINAL SCORE:**