

Written Quiz

- | | <u>POINTS</u> |
|--|----------------------|
| 1. How often should standpipe systems be inspected? | <u>10</u> |
| 2. What are the two types of standpipe inspections? | <u>20</u> |
| 3. How many classes of standpipe systems are available? | <u>10</u> |
| 4. During initial installation the system must be pressure tested at _____ psi for _____ hour(s) by the installer. | <u>20</u> |
| 5. Where a pressurized water tank is used, what should the minimum pressure be? | <u>10</u> |
| 6. How often should fire pumps be operated? | <u>10</u> |
| 7. For how long should fire pumps be operated during this test? | <u>10</u> |
| 8. How often should dry standpipe systems be hydrostatically tested? | <u>10</u> |

POINTS POSSIBLE: 100

POINTS DEDUCTED:

FINAL SCORE:

- | | <u>POINTS</u> |
|--|----------------------|
| 1. How often should standpipe systems be inspected? EVERY 6 MONTHS | <u>10</u> |
| 2. What are the two types of standpipe inspections? INITIAL, PERIODIC | <u>20</u> |
| 3. How many classes of standpipe systems are available? THREE | <u>10</u> |
| 4. During initial installation the system must be pressure tested at 200 psi for 2 hour(s) by the installer. | <u>20</u> |
| 5. Where a pressurized water tank is used, what should the minimum pressure be? 75 PSI | <u>10</u> |
| 6. How often should fire pumps be operated? WEEKLY | <u>10</u> |
| 7. For how long should fire pumps be operated during this test? 30 MINUTES | <u>10</u> |
| 8. How often should dry standpipe systems be hydrostatically tested? EVERY 5 YEARS | <u>10</u> |

POINTS POSSIBLE: 100

POINTS DEDUCTED:

FINAL SCORE: