

## POINTS

INSTRUCTIONS: This is a FILL IN test. Fill in the correct answer in the space provided.

1. What three conditions indicate the need for testing detectors? 20
  - a. \_\_\_\_\_
  - b. \_\_\_\_\_
  - c. \_\_\_\_\_
  
2. How often should the loop resistance be tested on cable type line detectors? 20
  - a. \_\_\_\_\_
  
3. What is the recommendation for fusible link replacement? 20
  - a. \_\_\_\_\_
  
4. Is cigarette smoke an acceptable test for smoke detectors? 20
  - a. \_\_\_\_\_
  
5. How long should detector records be maintained? 20
  - a. \_\_\_\_\_

**POINTS POSSIBLE:** 100

**POINTS DEDUCTED:**

**FINAL SCORE:**

## POINTS

INSTRUCTIONS: This is a FILL IN test. Fill in the correct answer in the space provided.

1. What three conditions indicate the need for testing detectors? 20
  - a. **INITIAL INSTALLATION**
  - b. **AFTER A FIRE**
  - c. **ELAPSED PERIOD OF USE**
  
2. How often should the loop resistance be tested on cable type line detectors? 20
  - a. **SEMI-ANNUALLY**
  
3. What is the recommendation for fusible link replacement? 20
  - a. **EVERY FIVE YEARS**
  
4. Is cigarette smoke an acceptable test for smoke detectors? 20
  - a. **NO**
  
5. How long should detector records be maintained? 20
  - a. **FIVE YEARS**

**POINTS POSSIBLE:** 100

**POINTS DEDUCTED:**

**FINAL SCORE:**